

Environmental/Occupational Health & Safety Management Program

2017-2018 Radon Program Review

| | |
|----------------------|--|
| CLIENT: | Randolph School District |
| DATE: | September 26, 2017 |
| CONDUCTED BY: | Thom Ritchie, Account Manager |
| CONTACT: | Patty Riemenschneider, Business Manager |
| TELEPHONE: | (507) 263-2151 |

Objective:

Provide the client with assistance in examining radon gas testing results and to review compliance recommendations.

Topics of Discussion:

- Review Written Radon Safety Plan and update as needed.
- Provide advisement on testing recommendation/requirements.
- Respond to regulatory agency correspondence as necessary.
- Provide updates on regulatory changes and/or new developments.
- Reviewed results.

Findings / Recommendations:

While radon testing is not required, the US Environmental Protection Agency (EPA) recommends radon testing is conducted in all frequently occupied rooms, at or below grade level, once every five years.

Within the District, radon testing occurred: 2004

For the most valid results, sampling should take place for 90-120 days over the heating season, in the lowest occupied area if testing does take place.

MEI can send a radon-testing proposal to the District upon request.